A-7/2/C-11, Capital City, Talwade - Chakan Road, Chakan MIDC, PH-IV, Village Nighoje, Tal. Khed, Dist. Pune-410 501, Maharashtra.

Mob+ 9545084620, 8421365421 CIN No. : U74900PN2013PTC149666

E-mail : environsafetyeng@gmail.com, gesec12@gmail.com

Recognised by Ministry of Environment and Forests (MoEF) / Central Pollution Control Board Govt. of India (CPCB) ISO 9001:2015, ISO 45001: 2018 and ISO 14001: 2015 Certified Company

TES	ST REPORT	
Test Report No: GESEC/PRO/2022-23/08/172	Report Date	23/08/2022
	Sample Details	ETP Outlet
Name & Address of the Customer — M/S.BG FASTENING AND ENGINEERING INDIA PVT LTD GUT NO.103 &104, VILLAGE PHAROLA TQ. PAITHAN, AURANGABAD.	Volume Of Sample	1 Lit plastic bottle
	Sample Status	Sealed
	Sample Collected	Envirotech Research Private
	Ву	Limited
	Date of Sample Collection	16/08/2022
	Sample Receipt Date	17/08/2022
	Analysis start Date	17/08/2022
	Analysis End Date	22/08/2022

Parameters	Results	MPCB Limits	Unit	Standard Method
PH	7.8	5.5 – 9.0	-	APHA 4500-H⁺-B
TDS	689	<2100	mg/lit	APHA 2540-C
TSS	62	<100	mg/lit	APHA 2540-D
BOD (3 days 27°C)	12	<30	mg/lit	APHA 5210-B
COD	28	<250	mg/lit	APHA 5220-B
Iron	0.32	<5.0	mg/lit	APHA 3111 B,
Sulphate (as SO ₄)	215	<1000	mg/lit	APHA 4500- SO ₄ -E
Oil and grease	2	<10	mg/lit	IS 3025 (Part 39)

Remarks: All parameters are within the MPCB Limit



Mr. Vinod Hande (Technical Manager) Reviewed & Authorized By

END OF REPORT

GREEN ENVIROUS

Consultant.

Terms and conditions

- The report is refer only to the sample tested and not applies to the bulk.
- The results shown in this test report may differ based on various factors including temperature, humidity, pressure, retention time etc.
- 3. The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, GESEC.
- 4. Samples will be retained for a period of seven (7) days after completion of analysis. Longer retention periods can be arranged, on request of the customer.
- 5. We strictly maintain the confidentiality of all test result of sample(s) collected by us/ supplied by customer and not revel to third party unless required by the statutory or legal requirement.
- MoEF approved Lab by Govt. of India. From date. 16/02/2022 to 04/12/2022.