

## TEST REPORT

Report No:	NLES/24-25/08/WW/RE/93	Issue Date	17/08/2024		
Name and Address of Customer	M/s.Tube Investments of India Ltd (Unit-Tube Products of India) Gate No.1358/1362,1364-1365,1397, At Post-Shirwal,Taluka-Khandala,District-Satara 412801.				
Discipline	Chemical	Date of Sample Collection	12/08/2024		
Group	Pollution & Environment	Date of receipt of sample in lab	13/08/2024		
Sub Group	Waste Water	Sample Quantity	02 Liter Plastic can		
Sample Description	STP Outlet	Sample Status	Sealed		
Sample collected by	Neetal Laboratories and Environmental Services Private Limited				
Start Date of Analysis	13/08/2024	End Date of Analysis	17/08/2024		
<b>Results</b>					
Sr. No.	Parameters	Results	Unit(s)	MPCB Limits	Methods
1	pH at 25°C	8.29	-	N. S	APHA 4500, H+, B: 23rd Ed.2017
2	Total Suspended Solids (TSS)	12.0	mg/l	<50	APHA2540, D, 23rd Ed. 2017
3	Chemical Oxygen Demand	50.2	mg/l	<100	IS 3025 (Part 58), 2006
4	Biochemical Oxygen Demand (BOD) 3 days at 27°C	11.0	mg/l	<30	IS 3025 (Part 44), 2019
Remark-The above results are within MPCB Limits.,N.S-Not Specified					

### Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

  
Reviewed By  
(Ms. Sadhana Kanase)



  
Authorized Signatory  
(Ms. Kalyani Gore)

\*\*\*\*\*End of Report\*\*\*\*\*