






Recognised by Ministry of Environment and Forests (MoEF) / Central Pollution Control Board Govt. of India (CPCB) and ISO/IEC 17025:2017 (NABL), ISO 9001:2015, ISO 45001 : 2018 and ISO 14001 : 2015 Certified Company

TEST REPORT

Test Report No: - GESEC/PRO/VSR/2023-24/08/454		Report Date	05/09/2023					
Name & Address of the Customer M/S Helical Springs (unit T.K precision Pvt. Ltd.) Plot no. 16,17 & 18 Gut no 378 , Waluj Budruk taluka Gangapur , Aurangabad								
Ventilation Survey Sample Details								
Sampling done by	Envirotech Research Private Limited							
Date of Sampling	29/08/2023							
Instrument/calibration details								
Name of Instrument	Digital Anemometer(FA1880068)							
Date of Calibration	30-06-2023	Due Date of Calibration	29-06-2024					
Calibration Certificate No.	(ACE/SD/ENVIROTECH2306A 5)							
Locations	Incoming Velocity m/s					Mean m/s	Observations	Remark
	1	2	3	4	5			
LINE -1 REAR	1.3	1.0	1.6	1.5	1.2	1.3	Adequate Air Movement	Comfortable
LINE -2 REAR	1.5	1.6	1.7	1.5	1.9	1.6	Adequate Air Movement	Comfortable
LINE -3 CLUTCH & FRONT	1.6	1.2	1.3	1.5	1.6	1.4	Adequate Air Movement	Comfortable
LINE -4 CLUTCH & FRONT	1.2	1.4	1.6	1.0	1.5	1.3	Adequate Air Movement	Comfortable
LINE -5 MONO LINE	1.1	1.3	1.2	1.1	1.5	1.2	Adequate Air Movement	Comfortable
INSPETION POWER COOLY	1.5	1.6	1.4	1.1	1.0	1.3	Adequate Air Movement	Comfortable
POWER COOTY LINE	1.4	1.2	1.0	1.6	1.3	1.3	Adequate Air Movement	Comfortable
Remark-								
<ul style="list-style-type: none"> ➤ The Factories Act 1948, Standards: ➤ In any factory at the height of 1.5 meters above the floor level the adequate air movement of at least 30 meters per minute (0.5 m/s) shall be provided. 								
								
					<p>Mr. Vinod Hande (Technical Manager) Reviewed & Authorized By</p>			

END OF REPORT

Terms and conditions

- The report is refer only to the sample tested and not applies to the bulk.
- The results shown in this test report may differ based on various factors including temperature, humidity, pressure, retention time etc.
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, GESEC.
- Samples will be retained for a period of seven (7) days after completion of analysis. Longer retention periods can be arranged, on request of the customer.
- We strictly maintain the confidentiality of all test result of sample(s) collected by us/ supplied by customer and not revel to third party unless required by the statutory or legal requirement.
- MoEF approved Lab by Govt. of India. From date. 16/02/2022 to 29/02/2024.