

TEST REPORT

Company Name & Address :	M/s. Speciality Sintered Products Private Limited Gat No. 409/1, Nanekarwadi, Chakan-Talegaon Road, Tal: Khed, Dist : Pune.
-------------------------------------	--

Inward No: SAEN/23-24/524 - VII	Date of Sampling : 13.03.2024
Your Ref No. : Test Request	Sampling Method: SAEN/SOP/S-03
Collected By : SAEN	Dates of Analysis : 14.03.2024 - 21.03.2024
Sample Name : Stack Monitoring	Sampling Location: DG Set (750 KVA)
Report No. : SAEN/TR/23-24/45-47	Date of Report : 22.03.2024

Sr. No	Parameters	Unit	Result	Limits As Per MPCB Consent
1	Duration Of Sampling	Minutes	30	
2	Type of Stack	--	Round	
3	Material of Stack	--	MS	
4	Height of Stack from GL	Meter	5.5	
5	Flue Gas temperature	⁰ C	122	
6	Diameter Of Stack	mtr	0.30	
7	Area of Stack	m ²	0.0707	
8	Flue Gas Velocity	m/s	3.1	
9	Gas Volume	Nm ³ /hr	788.5	
10	Total Particulate Matter	mg/Nm ³	30.7	< 150.00
11	Sulphur Dioxide	Kg/Day	2.97	< 4.00

Remarks (If Any): Above results are well within the limits prescribed by MPCB Consent.


Instrument Used : SAEN/Instru/59 A

Calibration Details: Cert. No. 9000 XT 222, valid till- 23.07.2024

Note:

1. Test Report is based on above parameters.
2. SAEN will discard the sample after 15 days from date of Test Report.
3. Test Results pertain only to the sample tested.
4. The content of Test Report shall not be reproduced / used for advertising or legal use, in part or full, without written permission.
5. Laboratory Recognized by NABL with Certificate ID : TC-12368, Valid till dt. 09.10.2025.

For SA Encon Private Ltd.



Mr. Anantrao Nandawadekar - Technical Manager

Authorized Signatory

END OF REPORT

SAEN/F-06 Amd 00 dt 08.06.2023

