

MAHALAKSHMI ENGINEERING & CONSTRUCTION PVT LTD.

Ref.No : MECPL /EHS/015/REV-0

TITLE : HAND & POWER TOOLS INSPECTION CHECKLIST

Project: MHDC SOLAPUR

CONTRACTOR NAME:- K.S. Buildcon.

Location: 128/3, Building.

Date: 05/05/2023 Time : 11:00 AM.

Inspected By: MR AZIM SHAIKH

SR NUMBER:-

Frequency: weekly

SL NO	DESCRIPTION	YES	No	TARGET DATE	REMARKS
1	Are handtools & other tools regularly inspected for safe condition?	✓			
2	Are tools Handles are free from splits & cracks?	✓			
3	Are handles wedged tightly in the heads of all tools.	✓			
4	Are impact tools free from mushroom head.	✓			
5	Are the head of chisels or punches ground periodically check to prevent Mushrooming?	✓			
6	Are the cutting edges kept sharp so the tool will move smoothly without binding or skipping.		✓		
7	Is the sharpening redressing or repairing tools done properly ,using tools suited to each purpose.	✓			
8	Are power saws and similar equipement provided with safety guards.	✓			
9	Are tools used with the correct shield, guard , or attachment recommended by manufacturers.	✓			
10	Are abrasive wheel grinders provided with safety guards which cover the spindle ends,nuts and flange projections.	✓			
11	Are portable circular saws equipped with guards above and below the base or shoe?	✓			
12	Are saw guard checked to assure they are not wedged up thereby leaving an unguarded lower portion of the blade.		✓		
13	Are guards kept in place and in working order.	✓			
14	Are rotating or moving parts of equipment provided with 360 degree guarding.		✓		
15	Is the operator wear eye and face protection when grinding.	✓			
16	Is the pneumatic hose line secured to the pneumatic tool.		✓		
17	Are tool bits secured by use of safety clips or retainers to prevent accidental disconnecting.	✓			
18	Are appropriate ground fault circuit interrupters provided at the job sites.	✓			
19	Are electric powered tools double insulated or properly grounded.	✓			
20	Are tools stored in a dry ,secure location where they won't be tampered.	✓			
21	Are the portable hand tools inspect at regular intervals.	✓			
22	Any other Points:-				

Signature : (MECPL PROJECT INCHARGE)

Signature:(MECPL EHS OFFICER)

(Handwritten signature)
K.S.



MAHALAKSHMI ENGINEERING & CONSTRUCTION PVT LTD.

Ref. No: MECPL/PROJ/REG/REG/2023/01

TITLE : HAND & POWER TOOLS INSPECTION CHECKLIST

Project: **MHDC SOLAPUR** Contractor Name: **Modern Construction**
 Location: **15816 Building** Date: **12/5/2023** Time: **10:00 AM**
 Inspected By: **MR AZIM SHAIKH** SR NUMBER:-

Frequency: weekly

SL NO	DESCRIPTION	YES	No	TARGET DATE	REMARKS
1	Are handtools & other tools regularly inspected for safe condition?	✓			
2	Are tools Handles are free from splits & cracks?	✓			
3	Are handles wedged tightly in the heads of all tools.	✓			
4	Are impact tools free from mushroom head.	✓			
5	Are the head of chisels or punches ground periodically check to prevent Mushrooming?	✓			
6	Are the cutting edges kept sharp so the tool will move smoothly without binding or skipping.		✓		
7	Is the sharpening redressing or repairing tools done properly ,using tools suited to each purpose.	✓			
8	Are power saws and similar equipment provided with safety guards.	✓			
9	Are tools used with the correct shield, guard , or attachment recommended by manufacturers.	✓			
10	Are abrasive wheel grinders provided with safety guards which cover the spindle ends,nuts and flange projections.	✓			
11	Are portable circular saws equipped with guards above and below the base or shoe?	✓			
12	Are saw guard checked to assure they are not wedged up thereby leaving an unguarded lower portion of the blade.		✓		
13	Are guards kept in place and in working order.	✓			
14	Are rotating or moving parts of equipment provided with 360 degree guarding.		✓		
15	Is the operator wear eye and face protection when grinding.	✓			
16	Is the pneumatic hose line secured to the pneumatic tool.	✓			
17	Are tool bits secured by use of safety clips or retainers to prevent accidental disconnecting.	✓			
18	Are appropriate ground fault circuit interrupters provided at the job sites.	✓			
19	Are electric powered tools double insulated or properly grounded.	✓			
20	Are tools stored in a dry ,secure location where they won't be tampered.	✓			
21	Are the portable hand tools inspect at regular intervals.	✓			
22	Any other Points:-				

Signature : (MECPL PROJECT INCHARGE)

Signature : (MECPL EHS OFFICER)