



MICROTRONICS

Opp. V.K. Height, Near City Post Office, Anguribagh, Aurangabad.
Ph. : 0240 - 2340459, 6504286, Mob: 9850090407
E-mail : microtronics_ups@rediffmail.com, laxmikant@microtronics.in

Plot No.54, Gut No.99, Behind A.S. Club, Near New Mhada Colony,
Waluj Mahanagar, CIDCO, Tisgaon, Aurangabad



Ref. :

Date :

22/05/2023

METHOD STATEMENT TEMPLET

SR. NO.	JOB STEP	IDENTIFY HAZARD AND ASSESMENT	CONTROLS
1	INSTALLATION & PREVENTIVE MAINTENANCE	SHORT CIRCUIT, BATTERIES FALLDOWN, WHICH MAY CAUSE HAND BURN, EYE INJURY, FEET ENJURY	USING PROPER & INSULATED TOOLS USING SAFETY SHOES, SAFTY GOGGLES & HAND GLOVES
2	BREAKDOWN	SHORT CIRCUIT CAUSE FIRE	USING PROPER & INSULATED TOOLS USING SAFETY SHOES, SAFTY GOGGLES & HAND GLOVES