

FORM - B

Govt.Of Maharashtra
Electrical Inspector
Electrical Inspection Division
Industry Energy & Labour Deptt.
PWD Camps, Infront of Renuka Petrol Pump,(Indian Oil Petrol Pump)
Powainaka Satara-415001

Date 07/11/2022 E-mail- eisatara.nrg-mh@gov.in Tel.No.02162234133

ANNUAL INSPECTION REPORT 2022-23
[ELECTRICITY ACT 2003 AND CENTRAL ELECTRICITY
AUTHORITY (SAFETY AND ELECTRICITY SUPPLY)
REGULATION 2010 (REG.30)]

NAME AND ADDRESS: M/s. Tube Investment of Indira Ltd.
OF CONSUMER
A.P. - Shival C.No-1357
Tal. Ichandale Dist. Satara

CONSUMER NO 20350 : TYPE OF CONSUMER : COMM./IND
TRANSFORMER CAPACITY 1600x2x33kw GENERATOR CAPACITY : 1975 kw
SANCTIONED LOAD : CONTRACT DEMOND :

REMARKS
① 1600 kw x 2 x 33kw = 2200 kw
② D.G. (650 + 650 + 600 + 75) = 1975 kw x 55%
③ Cool for Satara = 300 kw

- ① Submit all information and test report as per intimate letter
- ② Provide electrical safety after and authorized person list with required qualification and test report
- ③ Check double earthing arrangement of all HT, LT, D.G., Equipment and panel board machine & submit result along load list

NOTE: THE ABOVE SAID ELECTRICAL INSTALLATION IS INSPECTED ON BY UNDERSIGNED & MENTIONED REMARKS SHALL BE COMPLIED WITHIN 10 DAY & INTIMATE TO THIS OFFICE IMMEDIATELY

- 1) If, Not complied within time limit As per Regulation 2010, Rule No-30 M S E D Co.Ltd (Supply Company) will be intimated to disconnect your factory Supply.
- 2) As per letter by Chief Engg. (Elect.) P.W. Deptt. Govt. of Maharashtra, Letter No CE (Elect.)/4/134/2012 Dt. 8/1/2013 Inspection Fee is Stopped.

COMPANY REPRESENTATIVE

Anshul Gupta

(A.H. MUJAWAR)
ELECTRICAL INSPECTOR
SATARA

Mob.No. 9892457491