


FORM – 11
REPORT OF EXAMINATION OF HOIST, LIFT, LIFTING MACHINE, CHAINS, ROPES AND LIFTING TACKLE

(See Rule 62 & 64)

1	Name of the Occupier	:	MR MUKESH AHUJA
2	Name and address of the Factory	:	TUBE INVESTMENTS OF INDIA LTD. UNIT: TUBE PRODUCTS OF INDIA, Gat No.: 1358 to 1362, 1364, 1365 Shirwal P.O. Taluka Khandala, District Satara 412 801.
3A	Type, Identification numbers and description of hoist, lift, lifting machine, chains, ropes and lifting tackles.	:	Double Girder EOT Crane Sr. No.: Crane No. 1 (96/97/C/52) Safe Working Load: 5 Ton Make: WMI Location: CDW
3B	Date of construction or reconstruction and the date when the hoist, lift, lifting machine, chains, ropes and lifting tackles were first taken into use in the factory.	:	03-01-1996
4	Date of last examinations made under section 28(1)(a)(ii) and 29(1)(a)(iii) and by whom it was carried out.	:	31-12-2021 MANOJ SUDHAKAR PARDESHI
5A	Maintenance: (List of parts, if any, which were inaccessible) Are following parts of the hoist or lift properly maintained and in good working order? If not, state what defects have been found:	:	
	a) Enclosure of hoistway or liftway.	:	Not Applicable
	b) Landing Gates and Cage gate(s).	:	Not Applicable
	c) Interlocks on the landing gates and cage gate(s).	:	Not Applicable
	d) Other gates fastenings.	:	Not Applicable
	e) Cage and platform and fittings, cage guides, buffers, interior of the hoistway or liftway.	:	Not Applicable
	f) Overrunning devices.	:	OK
	g) Suspension ropes or chains and their attachments.	:	OK
	h) Safety gear i.e. arrangements for preventing fall of platform or cage brakes.	:	Not Applicable
	i) Brakes	:	OK
j) Work of spur gearing.	:	OK	
k) Other electrical equipment.	:	OK	
l) Other parts.	:	OK	
5B	Date and number of the certificate relating to any test and examination made under sub-rule (1) of rule 64 together with the name of the person who issued the certificates.	:	13-12-2022 RTV/TI/LM/12/2022/1 MANOJ SUDHAKAR PARDESHI
5C	i) Date of annealing or their heat treatment of the chain and lifting tackle carried out under sub-rule (5) of Rule 64 and by whom it was carried out.	:	Not Applicable Not Applicable
	ii) Particulars of any defect found at any such examination or after annealing and affecting the safe working load and of the steps taken to remedy such defect.	:	No any defect observed during testing and examination.
6	Repairs, renewals or alterations (if any) required and the period within which they should be executed and maximum safe working load subject to repairs, renewals or alterations (if any).	:	NIL

I/We certify that on **13-12-2022** I/We thoroughly examined the hoist or lift, lifting machine, ropes and lifting tackles and details of examination/tests carried out is enclosed herewith that the above is a correct report of the result.

Signature of Competent Person :




Name of Competent Person	:	MANOJ S. PARDESHI - CPC NO. P-036/2022
Qualification	:	DME and DIS
Address	:	RELIABLE TECHNO VENTURE B-4, Manish Park, Phase III, N.I.B.M. Road, Kondhwa, Pune 411 048 Phone No.: 020 26830155, M: 9823238484, 9890 6767 51 E-mail: fireandsafe@gmail.com, reliabletechv@rediffmail.com
Date	:	13-12-2022 DUE DATE: 12-12-2023


FORM – 11
REPORT OF EXAMINATION OF HOIST, LIFT, LIFTING MACHINE, CHAINS, ROPES AND LIFTING TACKLE

(See Rule 62 & 64)

1	Name of the Occupier	:	MR MUKESH AHUJA
2	Name and address of the Factory	:	TUBE INVESTMENTS OF INDIA LTD. UNIT: TUBE PRODUCTS OF INDIA, Gat No.: 1358 to 1362, 1364, 1365 Shirwal P.O. Taluka Khandala, District Satara 412 801.
3A	Type, Identification numbers and description of hoist, lift, lifting machine, chains, ropes and lifting tackles.	:	Double Girder EOT Crane Sr. No.: Crane No. 2 (TPI 53 B) Safe Working Load: 5 Ton Make: WMI Location: CDW
3B	Date of construction or reconstruction and the date when the hoist, lift, lifting machine, chains, ropes and lifting tackles were first taken into use in the factory.	:	03-01-1995
4	Date of last examinations made under section 28(1)(a)(ii) and 29(1)(a)(iii) and by whom it was carried out.	:	31-12-2021 MANOJ SUDHAKAR PARDESHI
5A	Maintenance: (List of parts, if any, which were inaccessible) Are following parts of the hoist or lift properly maintained and in good working order? If not, state what defects have been found:	:	
	a) Enclosure of hoistway or liftway.	:	Not Applicable
	b) Landing Gates and Cage gate(s).	:	Not Applicable
	c) Interlocks on the landing gates and cage gate(s).	:	Not Applicable
	d) Other gates fastenings.	:	Not Applicable
	e) Cage and platform and fittings, cage guides, buffers, interior of the hoistway or liftway.	:	Not Applicable
	f) Overrunning devices.	:	OK
	g) Suspension ropes or chains and their attachments.	:	OK
	h) Safety gear i.e. arrangements for preventing fall of platform or cage brakes.	:	Not Applicable
	i) Brakes	:	OK
5B	Date and number of the certificate relating to any test and examination made under sub-rule (1) of rule 64 together with the name of the person who issued the certificates.	:	13-12-2022 RTV/TI/LM/12/2022/2 MANOJ SUDHAKAR PARDESHI
	i) Date of annealing or their heat treatment of the chain and lifting tackle carried out under sub-rule (5) of Rule 64 and by whom it was carried out.	:	Not Applicable Not Applicable
5C	ii) Particulars of any defect found at any such examination or after annealing and affecting the safe working load and of the steps taken to remedy such defect.	:	No any defect observed during testing and examination.
	6	Repairs, renewals or alterations (if any) required and the period within which they should be executed and maximum safe working load subject to repairs, renewals or alterations (if any).	:

I/We certify that on **13-12-2022** I/We thoroughly examined the hoist or lift, lifting machine, ropes and lifting tackles and details of examination/tests carried out is enclosed herewith that the above is a correct report of the result.

Signature of Competent Person :




Name of Competent Person	:	MANOJ S. PARDESHI - CPC NO. P-036/2022
Qualification	:	DME and DIS
Address	:	RELIABLE TECHNO VENTURE B-4, Manish Park, Phase III, N.I.B.M. Road, Kondhwa, Pune 411 048 Phone No.: 020 26830155, M: 9823238484, 9890 6767 51 E-mail: fireandsafe@gmail.com, reliabletechv@rediffmail.com
Date	:	13-12-2022 DUE DATE: 12-12-2023