



Antyodaya Construction

📍 Gut No. 34, Plot No. 63, Balajinagar, Sahajapur, MIDC Waluj, Chh. Sambhajinagar-431133

📍 Gut No. 312, Plot 121, Ram Krushna Nagar, Wasmat Road, Parbhani-431401

E-mail : antyodayaconstruction58@gmail.com

GST : 27ACCFA6231H1ZN Mob. 9764449111,

Ref. No. AC-2024-25/ 32

Date : 02.09.2024

Method of Statement

Method of statement				
Scope of Work :- Fabrication and Height work				
Sr. No.	Steps Involved in the Job	Hazards	Controls	officials remark
1	Avail Work Permit	No control or safety	Avail work permit, conduct Tool Box Talk and make available all Safety PPE's on site	Will be followed as per standard.
	Skilled Manpower deployment on site	Unsafely actions by the unskilled manpower	Skilled manpower to be deployed for shifing work.	Skilled and insured availability of the ESIC and PF for them
2	Shifting of materials	Injury to body due to mishandling	Elated gloves to be used	Available
			Safety shoes, Helmet to be used	Available
3	Erection of Columns, Parlim & Supports	Lifting of Structure	Safety shoes, Helmet, hand gloves to be used by the operator & Crane to be used for lifting the structure	PPE's available & Skilled manpower is deploys and 12T Crane to be used for lifting the columns and Rafter.
		Fatal injury due to fall of structure	Tested slings to be used & trained manpower available under Strict supervision	Tested slings are available & trained manpower available under Strict supervision
		Instructions to working manpower at site	Safety Training & Safety Tool box talk to be provided to all workmen before start of relevant activity	TBT & Safety training conducted before start of every activity
		Tripping hazard due to site material laid on floor	SS to be maintained at site	During the work and before leaving the site SS will be maintained every day
4	Working on height	Fatal injury to workers due to fall from height	Standard ladder, Safety full body harness and appropriate PPE's to be used	Ensure for proper testing of ladder
		Injury to body due fall of tools, tackles and material	Area to be barricaded	Ensure for proper lighting arrangement
		Unauthorized entry restriction	Area to be barricaded during work.	Available
5	Closing of work permit	Tripping hazard due to un wanted material laying at site	Remove all unwanted material from the site	Noted & will be followed

For Antyodaya Construction

Authorized Signature