

DARSHAN ENTERPRISES

F-93, NEAR ZAMBAD CHOUK, MIDC WALUJ, AURANGABAD - 431136

MOB NO- 9326182845, 7028998093

EMAIL ID- darshanenterprises70@gmail.com

Activity	Sub-Acivities	R/NR	HAZARD	HAZARD NO	RISK	Present control	Hazard Categories			
							1 Catastrophic	2 Critical	3 Serious	4 Minor
Fire protection system AMC	Checking & maintenance of fire extinguishers,refilling,testing & replacement if spare parts if reouired	R	Chances of explosion while hydrotest,dusting exposure while refoling,hand injury while handling of FE	1	STF/Explosion/Ey eirritation/Injury	Regular monitoring of system	C	C	C	C
	Checking & maintenance water of water hydrant system	R	High pressure water may enter into eyes	2	Eye irritation/Injury	Regular monitoring of system	C	C	C	C
	Checking & maintenance of control panel	R	Chances of electric shock	3	Bodu injury/Death	Regular monitoring of system	B	B	B	B
	Checking & maintenance sprinklers system	R	High pressure water may enter into eyes	4	Eye irritation/Injury	Regular monitoring of system	C	C	C	C
	Checking & maintenance of hydrant pump/motor	R	Chances of electric shock	5	Bodu injury/Death	Regular monitoring of system	B	B	B	B
	Cheking & maintenance of manual call point/panel of fire alarm system	R	Chances of electric shock	6	Bodu injury/Death	Regular monitoring of system	C	C	C	C
	Checking & maintenance of CCTV	R	Chances of electric shock	6	Bodu injury/Death	Regular monitoring of system	C	C	C	C
	Checking & maintenance of control panel of gas leak detection system	R	Chances of electric shock	7	Bodu injury/Death	Regular monitoring of system	C	C	C	C

A	FREQUENT
B	PROBABLE
C	OCCASIONAL
D	REMOTE
E	IMPROBABLE

	UNACCEPTABLE
	HIGH
	MEDIUM
	LOW