

Installation Report

TO,

Date: 03/01/2023

RUCHA ENGINEERS PVT. LTD.

SHENDRA UNIT - 4C-59 Part-B Five Star

MIDC Shendra, Aurangabad

Dear Sir,

With the reference to your PO No. 1051000037 Dated 06/10/2022, We have successfully Installation & commission the RO Plant 1000 LPH, As on date 03/01/2023

We have maintained the technical part as below,

- 1) Ro Plant Outlet - 1000 LPH (50 sec) ppm
- 2) Outlet TDS Maintained - 10 ppm
- 3) Auto Tank Control maintained & Test


All Mechanical, Electrical & Plumbing work are execute with at most safety & longevity. Electrical safety is specially Rechecked & Confirm as Electrically safe. Still we always recommend to take all necessary Electrical safety precaution during usage.

During usage of Ro Plant please follow instruction as per SOP Sheet & maintain the Plant as per LOG Book. All necessary training to operator.

In case of any Assistance or technical Issue please feel free to contact us.
(Office contact No. 9561922894)

OK
03/01/2023
R.K. Parke

Pradip Waghmare



Design office:- X 51 BAJAJ NAGAR, Waluj Midc, Aurangabad, Maharashtra 431136 India E-mail:
hindustanwater.sale@gmail.com/ hindustanwater.sale@gmail.com Cell - 9975643257





Hindustan Water Treatment System

DISTAL WATER MANAGEMENT

Installation Report

TO,

Date: 21/12/2022

BADVE ENGINEERING LTD. UNIT-6A

B-5 & B6 MIDC INDUSTRIAL AREA, WALUJ
Aurangabad 43113

Dear Sir,

With the reference to your PO No. 4700007633 Dated 30.10.2021, We have successfully Installation & commission the RO Plant 500 LPH, As on 21/12/2022.

We have maintained the technical part as below,

- 1) Ro Plant Outlet – 500 ltr per Hour.
- 2) Outlet TDS Maintained – 25 ppm (70-80 ppm) - set
- 3) Auto Tank Control maintained & Test OK. Tested


All Mechanical, Electrical & Plumbing work are execute with at most safety & longevity. Electrical safety is specially Rechecked & Confirm as Electrically safe. Still we always recommend to take all necessary Electrical safety precaution during usage.

During usage of Ro Plant please follow instruction as per SOP Sheet & maintain the Plant as per LOG Book. All necessary training to operator.

In case of any Assistance or technical Issue please feel free to contact us.

(Office contact No. 9561922894)

Handwritten note:
21/12/22
21/12/22
Mail OK.



Design office:- X 51 BAJAJ NAGAR, Waluj Midc, Aurangabad, Maharashtra 431136 India E-mail:
hindustanwater.sale@gmail.com / hindustanwater.sale@gmail.com Cell - 9975643257



Installation & commission

Report

TO,

Date:20/12/2022

EXIMUS INFRA TECH SOLUTIONS LLP, UNIT 8P,
GUT NO 22,23 & 25 SHIVRAI, TQ. GANGAPUR,
AURANGABAD-431133, MAHARASHTRA

Dear Sir,

With the reference to your PO No. 4300021344 Dated 25.01.2022, We have successfully Installation & commission/ trail the STP PLANT 50 KLD, As on date-20/12/2022 with sample report Attached -1

We have Completed Installation as per below,

1) STP PLANT 50 KLD – As per Design

2) Piping, blower, pump, panel, tube media, MBBR work completed.

3) All trial completed & process for Testing.

All Mechanical, Electrical & Plumbing work are execute with at most safety & longevity. Electrical safety is specially Rechecked & Confirm as Electrically safe. Still we always recommend to take all necessary Electrical safety precaution during usage.

During usage of STP PLANT 50 KLD please follow instruction as per SOP Sheet & maintain the Plant as per LOG Book. All necessary training given to operator .



Hindustan water Treatment System

Pradeep Waghmare :-

Undersigned By-

Project Team – Mr.Chavan Sir

Note:- A/c Blower Issue as per mail communication still not resolved by Hindustan water Treatment team after resolved this report will sign. Again.

Design office:- X 51 BAJAJ NAGAR, Waluj Midc, Aurangabad, Maharashtra 431136 India E-mail:
hindustanwater.sale@gmail.com / hindustanwater.sale@gmail.com Cell - [9975643257](tel:9975643257)



Hindustan Water Treatment System

WATER MANAGEMENT

Installation Report

TO,

Date: 31.10.2022

ENDURANCE TECHNOLOGIES LIMITED

(DIE CASTING DIVISION) UNIT-II
L-6/3 M.I.D.C. INDUSTRIAL AREA WALUJ
AURANGABAD - 431136 Maharashtra India
CIN L34102MH1999PLC123296

Dear Sir,

With the reference to your PO No. 1400046564 & 1400046691, We have successfully Installation & commission the RO Plant 1000 LPH- 2 NO & 5000 LPH Tank with all accessory, As on date 31.10.2022


We have maintained the technical part as below,


- 1) Ro Plant Outlet – 1000 X 2 LPH
- 2) Outlet TDS Maintained – 65 PPM
- 3) Auto Tank Control maintained & Test.
- 4) All stand by pump installation & trial completed.
- 5) All UPVC Piping installation & completed.
- 6) All electrical connection completed.


All Mechanical, Electrical & Plumbing work are execute with at most safety & longevity. Electrical safety is specially Rechecked & Confirm as Electrically safe. Still we always recommend to take all necessary Electrical safety precaution during usage.

During usage of Ro Plant please follow instruction as per SOP Sheet & maintain the Plant as per LOG Book. All necessary training to operator.

In case of any Assistance or technical Issue please feel free to contact us.
(Office contact No. 9561922894)


Anil Kumar


Anil Kumar



Design office:- X 51 BAJAJ NAGAR, Waluj Midc, Aurangabad, Maharashtra 431136 India E-mail: hindustanwater.sale@gmail.com/ hindustanwater.sale@gmail.com Cell - 9975643257





Hindustan Water Treatment System

Installation Report

TO,

Date: 08/01/2023

BUCHA ENGINEERS PVT. LTD.

SHENDRA UNIT - 40/5/9 Part-B Five Star

MIDC Shendra, Aurangabad

Dear Sir,

With the reference to your PO No. 1051000037 Dated 06/10/2022, We have successfully installation & commission the RO Plant 1000 LPH, As on date 08/01/2023

We have maintained the technical part as below,

- 1) Ro Plant Outlet - 1000 LPH (50 set) ppm
- 2) Outlet TDS Maintained - 10 ppm
- 3) Auto Tank Control maintained & Test


All Mechanical, Electrical & Plumbing work are execute with at most safety & longevity. Electrical safety is specially Rechecked & Confirm as Electrically safe. Still we always recommend to take all necessary Electrical safety precaution during usage.

During usage of Ro Plant please follow instruction as per SOP Sheet & maintain the Plant as per LOG Book. All necessary training to operator.

In case of any Assistance or technical Issue please feel free to contact us.
(Office contact No. 9561922894)

OK
03/01/2023
B.K. Parke

Pradip Waghmare



Design office:- X 51 BAJAJ NAGAR, Waluj Midc, Aurangabad, Maharashtra 431136 India E-mail:
hindustanwater.sale@gmail.com/ hindustanwater.sale@gmail.com Cell - 9975643257

